

Client: Friends of Perdido Bay

11-28-95

Report#: 198194-99

INORGANICS—Wastewater

Site: 11 Mile Upper at 297A

Lab#: 198194-96

Parameter	Method	MRL	Results
Chlorate	300.0B	20	5100 $\mu\text{g/L}$
Chlorine Dioxide	2350 C	0.1	0.4 mg/L
Monochloramine	4500-Cl G	0.1	< 0.1 mg/L
Dichloramine	4500-Cl G	0.1	< 0.1 mg/L
Nitrogen Trichloride	4500-Cl G	0.1	< 0.1 mg/L

INORGANICS—Wastewater

Site: 11 Mile Lower Tidal

Lab#: 198197-99

Parameter	Method	MRL	Results
Chlorate	300.0B	20	1700 $\mu\text{g/L}$
Chlorine Dioxide	2350 C	0.1	0.4 mg/L
Monochloramine	4500-Cl G	0.1	< 0.1 mg/L
Dichloramine	4500-Cl G	0.1	< 0.1 mg/L
Nitrogen Trichloride	4500-Cl G	0.1	< 0.1 mg/L

P
83

11-30-95

Client: Friends of Perdido Bay

Report#: 198670-75

INORGANICS—Wastewater

Site: 11 Mile Creek Upper at 297A

Lab#: 198670-72

Parameter	Method	MRL	Results
Chlorate	300.0B	20	8700 µg/L
Chlorine Dioxide	2350 C	0.1	0.4 mg/L
Monochloramine	4500-CIG	0.1	< 0.1 mg/L
Dichloramine	4500-CIG	0.1	< 0.1 mg/L
Nitrogen Trichloride	4500-CIG	0.1	< 0.1 mg/L

INORGANICS—Wastewater

Site: 11 Mile Creek Lower Tidal

Lab#: 198673-75

Parameter	Method	MRL	Results
Chlorate	300.0B	20	3500 µg/L
Chlorine Dioxide	2350 C	0.1	0.4 mg/L
Monochloramine	4500-CIG	0.1	< 0.1 mg/L
Dichloramine	4500-CIG	0.1	< 0.1 mg/L
Nitrogen Trichloride	4500-CIG	0.1	< 0.1 mg/L

Maximum strength in drinking
water is 0.8 mg/L